

YELLOW JACKET® RSA Software Upgrade



Refrigeration System Analyzer

Version 1.11 introduced 2-13-14 Power-off is now done via a software menu option

The change was made in response to some complaints about system analyzers not turning off properly when you press the on/off switch. Instead of fully shutting down, sometimes they would just blink off and turn right back on. This software update provides a field installable solution for people who are having this problem.

One thing to note is that after installing version 1.11, the “on/off” switch becomes just an “on” switch. You have to go to the menu to turn the unit off.

